


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. मेमो. / एवा. / 2021.2022

Date 11/01/2022

It is certified that an inspection team headed by Nagar Swasthya Adhikari & A team of NPP Sitapur (Name of Officers with designation) from NPP Sitapur (Name of Department/Office) inspected the maharishi Vidya Mandir Lakshimpur Road Nripholepur Sitapur (Name & Address of the School) on 11/01/2022 and found that the Maharishi Vidya Mandir Sitapur (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of                     

Signature with Seal:   
 Name: नगर स्वास्थ्य अधिकारी  
 Designation: नगर पालिका परिषद  
सीतापुर

To

Principal  
M.V.M. Sr. Sec. School  
LKM. Road, Sitapur  
School No. 71205

(Name & Address of the institution)

# Jal Jeevan Mission

Har Ghar Jal



## District water testing laboratory, U.P Jal Nigam, Sitapur

Arya Nagar near water tank, Sitapur. Pin- 261001  
8979986782

### Test report

Sample ID U288093L361S2308690

### User Information

Name MAHARISHI VIDYA MANDIR Mobile: 8840774505

Email: Pin Code: 261001

Full Address: House No- ,Village- Gram Panchayat-NAIPALAPUR, Block- KHAIRABAD, District- SITAPUR, State- UTTAR PRADESH

### Sample description

Source of Sample: Schools Village: NAIPALAPUR

Gram Panchayat: NAIPALAPUR Block: KHAIRABAD

District: SITAPUR State: UTTAR PRADESH

Address: 261001 Remarks: letter no- MVM/stp/UP/ UP JAL NIGAM/21-22/53

Latitude: Longitude:

Date & time of sample collection 01.12.21 | 11:00 AM Date & time of sample received in lab 01.12.21 | 11:10 AM Date & time of sample analysed 01.12.21 | 02:39 PM Date & time of report generation 02.12.21 | 12:48 PM

### Test results

Report no 2308690

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS-10500	Permissible limit (in absence of alternate source) as per BIS-10500	Test result value	Remarks
1	Colour*	Hazen units	5	15	0	
2	Turbidity*	NTU	1	5	1.7	
3	pH*	NA	6.5-8.5	No Relaxation	7.2	
4	TDS*	Milligram/liter	500	2000	546	

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
5	Total Alkalinity (as Calcium Carbonate)*	Milligram/liter	200	600	412	
6	Chloride (as Cl)*	Milligram/liter	250	1000	57.4	
7	Fluoride (as F)*	Milligram/liter	1	1.5	0.48	
8	Total Hardness (As CaCO <sub>3</sub> )*	Milligram/liter	200	600	460	
9	Iron (As Fe)*	Milligram/liter	1	No Relaxation	0.0	
10	Nitrate (as NO <sub>3</sub> )*	Milligram/liter	45	No Relaxation	10.01	

**Note:**

- 1)\*indicates parameters that are not NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Authorised signatory  
Ankil Chauhan

**Jal Jeevan Mission aims at potable tap water supply to every home**

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by BMI Division @ICMR. Copyright ©copy NJJM 2020